The first content of the parties of the content of	n 1			I	In		lu .	
1.5	Reference	Recommendation The Roard should ensure that suitable and sufficient FRA's are completed for all	Risk Rating	Action  Contact site manager after covid	Responsible Person	Target date	Update	Completed
Management   Man	4.3.1		М		Fire Safety Manager	31/08/2020		
A				· ·				
1.5   1.5			м					
March and Annexes and Annexes and Protecting of the Control of t	422				Harlet Cafee & Flackson	24 /00 /2020		
A special months, functions of the designation recognition of the complete planes of the property of the complete planes of the complet	4.3.2				Health Safety & Fire Manager	31/08/2020	4.3.1.	
1-32   Management			м					
Section of System Finding are considered all and with dischargers and section of the section of	4.3.3			group.	Site Manager	31/08/2020		
1-12   1-12								
Proceedings of the control of the			L					
Section Content (Content Content Con	4.3.4			go through this group.	Site Manager	31/08/2020		
A the stand standard amount of MOD (10) and VIDE ACT (10)				To be developed and presented to				
The Section Section Section 1 is a section of the s	5.3.1		IVI		Fire Safety Manager	31/08/2020		
The board and control for National Numbers of the Control Numbers of					,	,,		
be beautiful control only of presented in control only only only only only only only on		The Board should develop 'as installed' drawings illustrating all fire	М	FSG via capital Planning				
Secretary accordance with other designation provided in ES OF 100 control or 100	5.3.2				Fire Safety Manager	31/08/2020		
1320 Section 1								
The based about Service as favor good the above information is.  1.3.1 A bound about service any large particles are in the service of the service and the ser	F 2 2		L		Fire Cofee Manager	24 /00 /2020		
Secretaria en un de consultar maintaine en un bounds  1.	5.3.3				Fire Sarety Manager	31/08/2020		
Seate Manager (1998)  In bland William Control			L					
Section Section Control on Control Activity Control Section (1997)  The Section Section Control Contro	5.3.4				Fire Safety Manager	31/08/2020		
The Search Andrew Comment Comm								
The Sur Principal Control Control on Principal Control	5.3.5		-		Site Manager	31/08/2020		
Be Based should make a finite of the same processor of the same pr	536		L		Fire Cofety Manager	2.100		
poly decumentation is understand in various present with Vot Col.  1.3.1 and inspectations, we interface are with Vot Col.  1.3.2 accessed for Not of the South Frozence of Col.  1.3.3 and Annual Col.  1.3.4 and Annual Col.  1.3.4 and Annual Col.  1.3.5	5.3.6			Site rKA	Fire Safety Manager	31/08/2020		
and responsible. In accordance with World No. 02.  The board hard responsible in more in the proof of control of the control o								
Description of the Stand Standard Recognition of the Sta			Н					
Second content of the Second found in Second content in Second content of the Second foundation of the Second foundatio	6.3.1			Policy review in next 3 months	Fire Safety Manager	31/08/2020		
The Board chould review for the The recommendation disclosed within 15 No. NS 15 MS			н					
Exist 1603 and abbequint officing are followed, relating to the relation of the included in 2000 audit  To be included in 2000 audit  To be included in 2000 audit  To be included in 2000 audit  The safety formation through the development of a declared for the converse are in 1600 and the converse are in	6.3.2	competent FSA's is of high importance	"	Review Resources	Nurse Director	Immediately		
La Sate Lumbrace Consider Supporting the efficient of Glorinalization of the Sate State St								
The Board board consider supporting the effective destination of the results of the substitution of the process	622		М	To be included in 2020	Eiro Cofoty Manager	24 /00 /2 22		
Experience on the found state may be development of a declarate free for the found state of the found state	6.3.3			To be included in 2020 audit	Fire Safety Manager	31/08/2020		
dustly action on the Board's instanct system.  In Board and confidence and action of the state o			L	To be actioned when appropriate				
The hard should ensure standards of househowing remaintained of and improved where receiving which were received and where your property improved in a considerate where the medical gas optices are above in a considerate with the Moral and the property special of the consideration o	6.3.4				Fire Safety Manager	31/08/2020		
Castal Department to be completed and recorded  The Based to Mode descrive the medical period service of the Se								
By the board should make the method gas opinions are stroked in processing and because the strike of			М					
scordinace with Infilit Oar of the steepock procedures updated to reference the bactools, our aim region procedures by cylinder of the bactools of the bactool	6.3.5			a frequent basis	Site Manager	Daily		
reference the location, use and emergency procedures for cylinder.  The Board Should more than the grade and a Spin in a high printing and monitored by 15C miles and monitored and monitored by 15C miles and monitored and monit								
management during a fire recident. The Board board strate that Benginevi is given in high priority and empired of all controllation invalued and gration sources, with design of all controllation invalued and gration sources, with design of all controllation invalued and gration sources, with design of all controllation invalued and gration sources, with design of all controllation invalued and gration sources.  The Board Should ensure that fined descript invaluables testing is completed for description invaluable in the source of the disposal of fines. PA. It is controlled for description invalued in the compartmentation invalued in the compartment in the compartment in the compartmen			М	To be included in review and				
he Beard should ensure that Surgistow As given a high printy and emption of all combastiles natural and givens outside and given outside and givens outside and givens outside and given outside and given outside and givens	6.3.6				Fire Safety Manager	31/08/2020		
sprovements is sativity implamentated to help prevent any further The Board broad consist of the State of the Control of the State of t				•				
The Board bould essure that fixed electrical installation resting is completed for Screen hospital, with certification provided in completed for Screen hospital, with certification provided in south of the state o			н					
the Board should ensure that fixed electrical installation testing is completed for Gorsenion Hospital, with criffication provided in decorative with the 15 and 55 772.  The Board Should reven the counter the administration of the state of			"					
completed for Granton Noticipals, with craffication provided in each section of the control of t	6.3.7			to be reviewed	Estates manager/Fire Safety Manager	31/08/2020		
Secretaries with #8.58 and 85 7671.  The Beard Solutior fearew the current fle altern soning arrangements, ensuring these are coordinated with the compartmentation, upon the control of the control of the compartmentation. Upon the control of the compartmentation of the compartmentation of the compartmentation. Upon the compartmentation of the compartmentation of the compartmentation. Upon the compartmentation of the compartmentation of the compartmentation. Upon the compartmentation and reconfiguration are described upon the compartmentation and reconfiguration and reconfiguratio				Estatos Danartmant to carry out				
The Board should review the current fire alarm soring arrangements, ensuring the sar our conflicted with the compartmentation. Upon completion, zone plains should be displayed adjucent to each fee work.  2.3.1 Alam panied. 2.3.2 Alam panied. 2.3.3 Alam panied. 2.3.3 Alam panied. 2.3.4 Description of the completion description of the completion description of the completion described to the displayed adjucent to each fee displayed fee disp	638		IVI		Estates Manager	31/08/2020		
ensuring these are coordinated with the compartmentation. Upon completion, once plans should be displayed adjacent to early red work  The Board should undertake a coordination exercise to ensure device between the carry out work  The Board should undertake a coordination exercise to ensure device work  The Board should undertake a coordination exercise to ensure device work  The Board should expect the Carry out work  The Board should expect the Carry out transfer of the Carry out work  The Board should expect the Carry out transfer of the Carry out work  The Board should expect the Carry out the Carry out work  The Board should expect the Carry	0.5.0				Estates manager	31/00/1010		
1.3.1 Along pairs should be displayed adjacent to early the Work Work Work Work Work Work Work Work								
The Board should undertake a coordination service to ensure device addresses all juvet from one feed faction and recording price done work.  The Board should update the C&E matrix, detailing the outcomes, all the post should ensure that it is accordance with \$5.5821, and 1 stated system is issualized, complete with the provision of as work on the post should ensure that it is accordance with \$5.5821, and 1 stated system is issualized, complete with the provision of as work on the post should ensure that it is accordance with \$5.5821, and 1 stated system is issualized, complete with the provision of as work on the post should ensure that it is accordance with \$5.5821, and 1 stated system is issualized, complete with the provision of as work on the post should ensure that the demostic type detectors are provided in the post should ensure that the disastence of a Repeat Price of the Post should ensure that bailing.  1. If the Board should ensure the complete fire allow system is the beard should ensure that condition and unnecessary activations. The Board should ensure the complete fire allow system is the post of the main should ensure that conditions are posted fally and in a timely should ensure that conditions are posted fally and in a timely should ensure the complete fire allow system is the complete fire allow system is the complete fire allow system is maintained in accordance with \$5.5831, including ensure allowed the post of the special system is the special system is the post of the special system is the post of the special system is the system is the special system is the provision of sales and post of system is the special system is the system is the special system is the speci		completion, zone plans should be displayed adjacent to each fire	M	Estates Department to carry out				
2.3.2 boundaries  The Board should update the C&E matrix, detailing the sounders, all work  The Board should update the C&E matrix, detailing the sounders, all work  The Board should update the C&E matrix, detailing the sounders, all work  The Board should update the C&E matrix, detailing the sounders, all work  The Board should ensure that in accordance with \$5.5839-1 and Li assessment of the state of th	7.3.1			work	Estates Manager	31/08/2020		
December 2015   December 201								
The Board should update the C&E matrix, detailing the sounders, sill work work work work work work work work	732		IVI		Estates Manager	31/08/2020		
The Board should ensure that the Sassay Land I standard system is installed, complete with the provision of as I standard system is installed, complete with the provision of as I standard system is installed, complete with the provision of as I standard system is installed, complete with the provision of as I standard system is installed, complete with the provision of as I standard system is installed, complete with the provision of as I standard system is installed, complete with the provision of as I standard system is installed, complete with the provision of as I standard system is installed, complete with the provision of as I standard system is unable to the companies of the companies	7.5.2				Litates manager	31/00/1010		
The Board should ensure that the accordance with \$5 4383-1, at 1 standard system in stallade drawing:  The Board should ensure that the domestic type detectors are removed, in order to avoid confusion and unnecessary activations  The Board should ensure that the domestic type detectors are expected for a standard condess the stallation of a Repeater Panel on the Work  The Board should consider the installation of a Repeater Panel on the Work  The Board should standar a review of the recording arrangements to Work  The Board should standar a review of the recording arrangements to Work  The Board should develop a full set of CAD fire drawings, including annual validation of the C&E.  The Board should develop a full set of CAD fire drawings, indicating the compartmentations unit way should then be implemented, the findings compartmentation and hazard room enclosures. A compartmentation and hazard room enclosures are rectified.  The Board should review the existing maintenance arrangements to ensure all designated fire doors are installed and maintained as a condingly  The Board should saves the emergency lighting illumination levels for compliance with the letter sharders, including the provision of the States Department to review  Estates Department to review  Estates Manager  31/08/2020  Estates Manager	7.3.3		М		Estates manager/Fire Safety Manager	31/08/2020		
Modelled drawings   Work   Estates Manager   31/08/2020								
The board should ensure that the domestic type detectors are 2,35 e moved, in order to avoid confusion and unnecessary activations work. Estates Department to carry out work. The board should consider the installation of a Repeater Panel on the estates Department to carry out work. Estates Manager 31/08/2020 The Dead should ensure the complete fire alarm system is maintained in accordance with 85 \$839, including annual volidation work. Work. Estates Department to carry out work. Estates Manager 31/08/2020 The Dead should review the existing maintenance arrangements to encourage and principles of which should be prioritised for action encourage. A compartmentation survey should then be implemented, the findings of which should be prioritised for action and principles of the Dead Should review the existing maintenance arrangements to ensure al designated fire does are installed and maintained as necessary and the deficiencies identified through the risk assessment procedure and the deficiencies identified through the risk assessment procedure and the deficiencies identified through the risk assessment procedure and the deficiencies identified through the risk assessment procedure and the deficiencies identified through the risk assessment procedure in the deficiencies identified through the risk assessment procedure in the deficiencies identified through the risk assessment procedure in the deficiencies identified through the risk assessment procedure in the deficiencies identified through t			M	Estates Department to carry out				
voice   content to avoid confusion and unnecessary activations   voice   content to avoid confusion and unnecessary activations   voice   content to array out   content to array out   voice   content to array out   voice   content to array o	7.3.4	installed drawings			Estates Manager	31/08/2020		
The Board should consider the installation of a Repeater Panel on the Lord Thor of the main building.  The Board should initiate a review of the recording arrangements to ensure all fire alarm surfactions are reported by and in a timely maintained in accordance with 85 839, including annual validation of the C&E.  The Board should develop a full set of CAD fire drawings, indicating the compartmentation, sub- unserve the complete fire alarm system is maintained in accordance with 85 839, including annual validation of the C&E.  The Board should develop a installed and maintained as necessary.  The Board should review the existing maintenance arrangements to ensure all designated fire doors are installed and maintained as necessary and the deficiencies identified through the risk assessment for compliance with the latest standards, including the provision of a Board should review the existing maintenance arrangements to ensure all designated fire doors are installed and maintained as necessary and the deficiencies identified through the risk assessment for compliance with the latest standards, including the provision of a Board should severe mergency lighting illumination levels for compliance with the latest standards, including the provision of a Board should severe mergency lighting is tested as necessary.  Consideration should also be given to a programme for renewing the example of the Board should severe points shall and a provision of a Board should severe points shall and a provision of a Board should severe points and areas.  The Board should severe points affect the provision of a develop of a situalled maintenance and provision of a Board should severe points affect and provision of a Board should develop of a situalled maintenance and provision of a Board should develop of a situalled maintenance and provision of a Board should develop of a situalled maintenance and provision of a Board should develop of a situalled maintenance and provision of a Board should develop of a situalled maintenance and pro	725		L		Estatos Managos	24 /00 /2 222		
The Board should inside a review of the recording arrangements to ensure all five alarm activations are reported fully and in a timely manner.  The Board should ensure the complete fire alarm system is maintained in accordance with 85 \$539, including annual validation of the C&E.  The Board should ensure with 85 \$393, including annual validation of the C&E.  The Board should every experimentation and hazard room enclosures. A compartmentation and hazard room enclosures. A compartmentation and hazard room enclosures. A compartmentation surely should then the implemented, the findings of which should be prioritised for action accordingly.  The Board should review the existing maintenance arrangements to ensure all designed fire doors are installed and maintained as more should be prioritised for action accordingly.  The Board should seases the emergency lighting illumination levels for compliance with the latest standards, including the provision of the Board should seases the emergency lighting is tested as necessary.  The Board should seases the emergency lighting is tested as necessary.  The Board should every lighting is tested as necessary.  The Board should every lighting is tested as necessary.  The Board should every lighting is tested as necessary.  The Board should every lighting is tested as necessary.  The Board should every lighting is tested as necessary.  The Board should every lighting is tested as necessary.  The Board should every lighting is tested as necessary.  The Board should every lighting is tested as necessary.  The Board should every lighting is tested as necessary.  The Board should every lighting is tested as necessary.  The Board should every lighting is tested as necessary.  The Board should every lighting is tested as necessary.  The Board should every lighting is tested as necessary.  The Board should every lighting is tested as necessary.  The Board should every lighting is tested as necessary.  The Board should every lighting is tested as necessary.  The Board should every light	7.3.3				cstates ivianager	31/08/2020		
The Board should initiate a review of the recording arrangements to ensure all fire alarm activations are reported fully and in a timely and a second control of the second cont	7.3.6		L		Estates Manager	31/08/2020		
ensure all fire alarm activations are reported fully and in a timely Table 1973.7 manner.  The Board should ensure the compilete fire alarm system is maintained in accordance with 85 5339, including annual validation of the C&E.  Beard should develop a full set of CAD fire drawings, indicating the compartmentation, sub-compartmentation and hazard room enclosures. A compartmentation sure yebout then be implemented, the findings of which should be prioritised for action accordingly.  The Board should review the existing maintenance arrangements to ensure all designated fire doors are installed and maintained as ensure and designated fire doors are installed and maintained as ensure and designated fire doors are installed and maintained as ensure and designated fire doors are installed and maintained as ensure and designated fire doors are installed and maintained as ensure and designated fire doors are installed and maintained as ensure and designated fire doors are installed and maintained as ensure and designated fire doors are installed and maintained as ensure and designated fire doors are installed and maintained as ensure and designated fire doors are installed and maintained as ensure and designated fire doors are installed and maintained as ensure and designated fire doors are installed and maintained as ensure and designated fire doors are installed and maintained as ensure and designated fire doors are installed and maintained as ensure and designated fire doors are installed and maintained as ensure and designated fire doors are installed and maintained as ensure and designated fire doors are installed and maintained as ensure and designated fire doors are installed and maintained as ensure and designated fire doors are installed and maintained as ensure and designated fire doors are installed and maintained as ensure and designated fire doors are installed and maintained as ensure and designated fire doors are installed and maintained as ensure and designated fire doors are installed and maintained as						31,03/2020		
The Board should ensure the complete fire alarm system is maintained in accordance with 85 \$839, including annual validation of the C&E.  The Board should develop a full set of CAD fire drawings, indicating the compartmentation survey should then be implemented, the findings of which should be prioritised for action accordingly  Based of the C&E.  The Board should review the existing maintenance arrangements to ensure all designated fire doors are installed and maintained as necessary and the deficiencies identified through the risk assessment or compliance with the latest standards, including the provision of adequate lighting to all external escape routes.  Based should assess the emergency lighting illumination levels for compliance with the latest standards, including the provision of adequate lighting to all external escape routes.  Based should assess the emergency lighting is tested as necessary.  Consideration should also be given to a programme for renewing the existing system.  Based should excernal escape routes.  The Board should excernal escape routes with the latest standard escape routes.  The Board should excernal escape routes.  The Board should excernal escape routes are sometiment of the first and in conjunction work of the excernal escape routes are sometiment of the escape routes are someti			L					
maintained in accordance with BS 5839, including annual validation work Estates Department to carry out work Estates Manager 31/08/2020  The Board should develop a full set of CAD fire drawings, including the compartmentation, sub-compartmentation and hazard room enclosures. A compartmentation survey should then be implemented, the findings of which should be prioritised for action scordingly  The Board should review the existing maintenance arrangements to ensure all designated fire doors are installed and maintained as necessary and the deficiencies identified through the risk assessment process are rectified.  The Board should ensure emergency lighting is littlend to review in the latest standards, including the provision of the Board should ensure emergency lighting is tested as necessary.  Consideration should also be given to a programme for renewing the example of the Board should ensure where the should develop 'as installed' emergency escape lighting of the development of more suitable hard standing surface areas, for egress of the Board should ensure that high priority is placed upon the development of more suitable hard standing surface areas, for egress of the Board should ensure that high priority is placed upon the development of more suitable hard standing surface areas, for egress of the Board should ensure that high priority is placed upon the development of more suitable hard standing surface areas, for egress of the Board should ensure that high priority is placed upon the development of more suitable hard standing surface areas, for egress of the Board should ensure that high priority is placed upon the development of more suitable hard standing surface areas, for egress of the Board should develop and the Ward areas.  The Board should enveloped to the RFS and in conjunction of the Board should develop coperation and coordination procedures of the Board should develop coperation and coordination procedures of the RFS and in conjunction of the RFS and in conjunction of the RFS and in conjunct	7.3.7			System to be reviewd	Site Manager	31/08/2020		
The Board should evelop a full set of CAD fire drawings, indicating the compartmentation, sub-compartmentation and hazard room enclosures. A compartmentation survey should then be implemented, the findings of which should be prioritised for action and hazard room enclosures. A compartmentation survey should then be implemented, the findings of which should be prioritised for action and hazard room enclosures. A compartmentation survey should then be implemented, the findings of which should be prioritised for action ensure all designated fire doors are installed and maintained as necessary and the deficiencies identified through the risk assessment ensure all designated fire doors are installed and maintained as necessary and the deficiencies identified through the risk assessment for compliance with the latest standards, including the provision of adequate lighting to all external escape routes.  The Board should ensure emergency lighting is tested as necessary. Consideration should also be given to a programme for renewing the states of the provision of a special planting to an environment of the provision of a special planting to an extended self-testing system.  8.3.4 escape lighting to all external escape routes.  The Board should ensure emergency lighting is tested as necessary. Consideration should also be given to a programme for renewing the extension should also be given to a programme for renewing the extension should also be given to a programme for renewing the extension should evelop rais installed emergency escape lighting to all external escape routes.  The Board should evelop rais installed emergency escape lighting of an extension of the states Department to carry out work of the states danages and the states Department to carry out work of the states danages and the states Department to carry out work of the states Manager and the sta				Estatos Donartm				
The Board should develop a full set of CAD fire drawings, indicating the compartmentation, sub-compartmentation and hazard room enclosures. A compartmentation survey should then be implemented, the findings of which should be prioritised for action.  8.3.1 accordingly  The Board should review the existing maintenance arrangements to ensure all designated fire doors are installed and maintained as necessary and the deficiencies identified through the risk assessment process are rectified.  8.3.2 process are rectified  The Board should assess the emergency lighting illumination levels for compiliance with the latest standards, including the provision of soft and including the provision of states of the provision of the states of the sta	738		IVI		Estates Manager	21/09/2020		
the compartmentation, sub- compartmentation and hazard room enclosures. A compartmentation survey should then be made implemented, the findings of which should be prioritised for action  8.3.1 accordingly  The Board should review the existing maintenance arrangements to ensure all designated fire doors are installed and maintained as necessary and the deficiencies identified through the risk assessment and ensure all designated fire doors are installed and maintained as necessary and the deficiencies identified through the risk assessment and the process are rectified.  The Board should assess the emergency lighting illumination levels for compiliance with the latest standards, including the provision of a good quality of the part of the pa	7.3.0				Correct initialiales	31/08/2020		
enclosures. A compartmentation survey should then be implemented, the findings of which should be prioritised for action 3.1.1 accordingly  The Board should review the existing maintenance arrangements to ensure all designated fire doors are installed and maintained as necessary and the deficiencies identified through the risk assessment process are rectified  8.3.2 process are rectified  The Board should assess the emergency lighting illumination levels for compliance with the latest standards, including the provision of adequate lighting to all external escape routes.  8.3.3 adequate lighting to all external escape routes.  The Board should ensure emergency lighting is tested as necessary. Consideration should also be given to a programme for renewing the 8.3.4 escape lighting to an entworked self-testing system.  8.3.5 drawings.  The Board should ensure that high priority is placed upon the development of more suitable hard standing surface areas, for egress of the Board should ensure that high priority is placed upon the development of more suitable hard standing surface areas, for egress or received and support the surface areas, for egress or received and support the surface areas, for egrees or reviewed.  8.3.4 person of the Board should ensure that high priority is placed upon the development of more suitable hard standing surface areas, for egrees or reviewed.  8.3.5 procedures  The Board should ensure that regular exercises are completed for staff and patients, with the involvement of the FRS and in conjunction of the Board should ensure that regular exercises are completed for staff and patients, with the involvement of the FRS and in conjunction of the Board should evelop cooperation and coordination procedures  The Board should evelop cooperation and coordination procedures  The Board should evelop cooperation and coordination procedures								
Estates Department to review  Estates Manager  31/08/2020  The Board should review the existing maintenance arrangements to ensure all designated fire doors are installed and maintained as necessary and the deficiencies identified through the risk assessment  8.3.2 process are rectified  The Board should assess the emergency lighting illumination levels for compliance with the latest standards, including the provision of procedures  The Board should assess the emergency lighting is tested as necessary.  Consideration should also be given to a programme for renewing the 8.3.4 escape lighting to a networked self-testing system.  The Board should evelop' as installed' emergency escape lighting to an etworked self-testing system.  Basic drawings.  The Board should ensure that high priority is placed upon the development of more suitable hard standing surface areas, for egress of the Board should ensure that high priority is placed upon the development of more suitable hard standing surface areas, for egress of the Board should ensure that regular exercises are completed for staff and patients, with the involvement of the RS and in conjunction of the Board should ensure that regular exercises are completed for staff and patients, with the involvement of the RS and in conjunction of the Board should evelop procedures  The Board should ensure that regular exercises are completed for staff and patients, with the involvement of the RS and in conjunction of the Board should evelop cooperation and coordination procedures  The Board should evelop cooperation and coordination procedures  Estates Department to review  Estates Manager  States Manager  31/08/2020  Estates Manager  31/08/2020			М					
The Board should review the existing maintenance arrangements to encessary and the deficiencies identified through the risk assessment an excessary and the deficiencies identified through the risk assessment an excessary and the deficiencies identified through the risk assessment an excessary and the deficiencies identified through the risk assessment an excessary and the deficiencies identified through the risk assessment an excessary and the deficiencies identified through the risk assessment an excessary and the deficiencies identified through the risk assessment an excessary and the deficiencies identified through the risk assessment an excessary and the deficiencies identified through the risk assessment an excessary and the deficiencies identified through the risk assessment an excessary and the deficiencies identified through the risk assessment an excessary and the deficiencies identified through the risk assessment an excessary.  In the Board should develop as installed an emission of the RS and in conjunction and the review and the provision of the RS and in conjunction and the review and the provision of the RS and in conjunction and the review and the provision of the RS and in conjunction and the review and the provision of the RS and in conjunction and the review and the provision of the RS and in conjunction and the review and the provision of the RS and in conjunction and the review and the provision of the RS and in conjunction and the review and the provision of the RS and in conjunction and coordination procedures are such that the involvement of the RS and in conjunction and the provision of the RS and in conjunction and the provision of the RS and in conjunction and the provision of the RS and in conjunction and the provision of the RS and in conjunction and the provision of the RS and in conjunction and the provision of the RS and in conjunction and the provision of the RS and in conjunction and the provision of the RS and in conjunction and coordination procedures are such as the provisio		implemented, the findings of which should be prioritised for action						
ensure all designated fire doors are installed and maintained as necessary and the deficiencies identified through the risk assessment  8.3.2 process are rectified  The Board should assess the emergency lighting illumination levels for compliance with the latest standards, including the provision of standards, including the provision of beautiful the latest standards, including the provision of standards and equate lighting to all external escape routes.  The Board should also be given to a programme for renewing the states Department to review beat states Department to carry out work  8.3.4 escape lighting to a networked self-testing system.  The Board should evelop's a installed and evelop's a installed and evelop as a strain of evelop and bring it is a state of the provision of the states Department to carry out work  8.3.5 drawings.  The Board should evelop's a installed and evelop and bring it is a state of the provision of the states Department to carry out work  8.3.6 drawings.  The Board should evelop and bring up to date evelop and bring up to date evelopation of the Board should evelop and bring up to date evelopation of the States Department to carry out work  8.3.7 be Board should evelop and bring up to date evelopation of the States Department to carry out work  8.3.8 bring the provision of the States Department to carry out work  8.3.9 procedures  The Board should redevelop and bring up to date evelocation of the States Department to carry out work  8.4 Estates Department to carry out work  8.5 Estates Manager  8.1/08/2020  8.5 Estates Manager  9.3.1 (States Manager  9.3.2 procedures  The Board should evelope and bring up to date evelocation of the States Manager  9.3.3 with the redevelopment of procedures  The Board should redevelop and bring up to date evercuation of the States Manager  Fire drill to be arranged  Site Manager  9.3.1/08/2020	8.3.1			Estates Department to review	Estates Manager	31/08/2020		
necessary and the deficiencies identified through the risk assessment  The Board should assess the emergency lighting illumination levels for compliance with the latest standards, including the provision of 8.3.3 adequate lighting to all external escapes routes.  The Board should also be given to a programme for renewing the 8.3.4 escape lighting to a networked self-testing system.  The Board should develop 'as installed' emergency escape lighting 8.3.5 drawings.  The Board should ensure that high priority is placed upon the development of more suitable hard standing surface areas, for egress 9.3.1 routes leading out and away from the Ward areas.  The Board should ensure that high priority is placed upon the development of more suitable hard standing surface areas, for egress 9.3.1 routes leading out and away from the Ward areas.  The Board should ensure that rigular exercises are completed for suffard and patients, with the involvement of the RFS and in conjunction 9.3.3 with the redevelopment of procedures  The Board should ensure that regular exercises are completed for suffard and patients, with the involvement of the RFS and in conjunction  The Board should ensure that regular exercises are completed for suffard and patients, with the involvement of the RFS and in conjunction  The Board should evelop cooperation and coordination procedures  The Board should evelop cooperation and coordination procedures  The Board should evelop cooperation and coordination procedures								
Estates Department to review   Estates Manager   31/08/2020			М					
The Board should assess the emergency lighting literation for compliance with the latest standards, including the provision of Manager and adequate lighting to all external escape routes.  The Board should ensure emergency lighting is tested as necessary. Consideration should also be given to a programme for renewing the Manager and the states of the	8.3.2			Estates Department to review	Estates Manager	31/08/2020		
for compliance with the latest standards, including the provision of 8.3.3 adequate lighting to all external escape routes.  The Board should ensure emergency lighting is tested as necessary. Consideration should also be given to a programme for renewing the 8.3.4 escape lighting to a networked self-testing system.  The Board should develop 'as installed' emergency escape lighting work.  The Board should ensure that high priority is placed upon the development of more suitable hard standing surface areas, for egress of the Board should ensure that high priority is placed upon the development of more suitable hard standing surface areas, for egress work.  The Board should ensure that regular exercises are completed for successful and particular that the surface areas are completed for eviewed  The Board should ensure that regular exercises are completed for successful and patients, with the involvement of the RFS and in conjunction of the Board should ensure that regular exercises are completed for successful and patients, with the involvement of the RFS and in conjunction of the Board should ensure that regular exercises are completed for successful and patients, with the involvement of the RFS and in conjunction of the Board should evelop cooperation and coordination procedures  The Board should evelop cooperation and coordination procedures  The Board should evelop cooperation and coordination procedures					<u>.</u>	22, 23, 2020		
The Board should ensure emergency lighting is tested as necessary. Consideration should also be given to a programme for renewing the escape lighting to a networked self-testing system.  The Board should develop as installed emergency escape lighting The Board should ensure that high priority is placed upon the development of more suitable hard standing surface areas, for egress 9.3.1 routes leading out and away from the Ward areas. The Board should ensure that require exercises are completed for staff and patients, with the involvement of the RFs and in conjunction 9.3.3 with the redevelopment of procedures The Board should ensure that regular exercises are completed for staff and patients, with the involvement of the RFs and in conjunction The Board should ensure that regular exercises are completed for staff and patients, with the involvement of the RFs and in conjunction The Board should ensure that regular exercises are completed for staff and patients, with the involvement of the RFs and in conjunction The Board should evelop cooperation and coordination procedures		for compliance with the latest standards, including the provision of	М					
Consideration should also be given to a programme for renewing the escape lighting to a networked self-testing system.  The Board should develop "as installed" emergency exape lighting and the board should ensure that high priority is placed upon the development of more suitable hard standing surface areas, for egress and the surface areas, for egress and the surface areas, for egress are completed for surface areas, for egress and the surface	8.3.3			Estates Department to review	Estates Manager	31/08/2020		
8.3.4 escape lighting to a networked self-testing system. work Estates Manager 31/08/2020  8.3.5 The Board should develop 'as installed' emergency escape lighting work Estates Department to carry out work Estates Manager 31/08/2020  8.3.5 The Board should ensure that high priority is placed upon the development of more suitable hard standing surface areas, for egress work Estates Department to carry out work Estates Manager 31/08/2020  9.3.1 routes leading out and away from the Ward areas. work Estates Department to carry out work Estates Manager 31/08/2020  9.3.2 procedures								
The Board should develop 'as installed' emergency escape lighting drawings.  The Board should ensure that high priority is placed upon the development of more suitable hard standing surface areas, for egress of the Board should ensure that high priority is placed upon the development of more suitable hard standing surface areas, for egress of the Board should redevelop and away from the Ward areas.  The Board should redevelop and bring up to date evacuation of the Board should ensure that regular exercises are completed for staff and patients, with the involvement of the FRS and in conjunction of the Board should develop cooperation and coordination procedures  The Board should evelop cooperation and coordination procedures  The Board should evelop cooperation and coordination procedures  The Board should evelop cooperation and coordination procedures  Lestates Department to carry out work  Estates Manager  States Manager  31/08/2020  Evacuation procedure to be reviewed  Site Manager  Fire drill to be arranged  Site Manager  31/08/2020	924		М		Estates Manager	21/00/2020		
8.3.5 drawings. work Estates Manager 31/08/2020  The Board should ensure that high priority is placed upon the development of more suitable hard standing surface areas, for egress work Estates Department to carry out work Estates Manager 31/08/2020  The Board should redevelop and bring up to date evacuation you call the Board should redevelop and bring up to date evacuation of the Board should redevelop and bring up to date evacuation of the Board should ensure that regular exercises are completed for staff and patients, with the involvement of the FRS and in conjunction 9.3.3 with the redevelopment of procedures  The Board should ensure that regular exercises are completed for staff and patients, with the involvement of the FRS and in conjunction 9.3.3 with the redevelopment of procedures  Fire drill to be arranged Site Manager 31/08/2020	0.3.4				Estates ividiiagei	31/08/2020		+
The Board should ensure that high priority is placed upon the development of more suitable hard standing surface areas, for egress  9.3.1 routes leading out and away from the Ward areas.  The Board should redevelop and bring up to date evacuation  9.3.2 procedures  The Board should ensure that regular exercises are completed for staff and patients, with the involvement of the FRS and in conjunction  9.3.3 with the redevelopment of procedures  The Board should evelop cooperation and coordination procedures  The Board should evelop cooperation and coordination procedures	8.3.5		L		Estates Manager	31/08/2020		
development of more suitable hard standing surface areas, for egress  3.1 routes leading out and away from the Ward areas.  The Board should redevelop and bring up to date evacuation  9.3.2 procedures  The Board should ensure that regular exercises are completed for staff and patients, with the involvement of the FRS and in conjunction  9.3.3 with the redevelopment of procedures  The Board should ensure that regular exercises are completed for staff and patients, with the involvement of the FRS and in conjunction  Fire drill to be arranged  Site Manager  31/08/2020  Fire drill to be arranged  Site Manager  31/08/2020						31,00,2020		
9.3.1 routes leading out and away from the Ward areas.		development of more suitable hard standing surface areas, for egress	Н	Estates Department to carry out				
9.3.2 procedures	9.3.1				Estates Manager	31/08/2020		1
The Board should ensure that regular exercises are completed for staff and patients, with the involvement of the FRS and in conjunction  9.3.3 with the redevelopment of procedures  The Board should develop cooperation and coordination procedures  Site Manager  31/08/2020			М		a:			
staff and patients, with the involvement of the FRS and in conjunction  9.3.3 with the redevelopment of procedures  The Board should develop cooperation and coordination procedures	9.3.2			reviewed	Site Manager	31/08/2020		
9.3.3 with the redevelopment of procedures Fire drill to be arranged Site Manager 31/08/2020  The Board should develop cooperation and coordination procedures			М					
The Board should develop cooperation and coordination procedures	9.3.3			Fire drill to be arranged	Site Manager	31/08/2020		
51/08/2020 one wanager 51/08/2020	9.3.4	for all departments	IVI	To be discussed at FSG	Site Manager	31/08/2020		